



# INSPECTION REPORT

**Report Issued:** Oct 19, 2021

**Inspection Result:**

**PARTIAL PASS**

**Permit Number:** SPRMH210082

**Issuance Date:** Aug 23, 2021

**Property Address:** 2305 MT WERNER CIR;

**Contractor:** Deans Plumbing and Heating Inc 192 East Line Street Bishop , CA 93514  
**To construct:** Installing underground mains,insulation,tubing,manifolds,above ground piping,and pumps to be connected to the flat plate heat exchanger in the mechanical room for the snowmelt system.

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** hydronic heat tubes and main line out to promenade area held 100 psi for 15 minutes with R5.6 installed below tubes, from One Steamboat Place working north to the Goldwalk escalator is all approved, some sections installed are temporary for this season by the Goldwalk area, will be removed and re-installed in CY2022 when building is built by goldwalk, blue paint laid out for temporary sections over foam. Will need to re-inspect sensors

**Corrections:**

Sincerely,

Todd Carr  
Building Official  
tcarr@co.routt.co.us