



INSPECTION REPORT

Report Issued: Oct 19, 2021

Inspection Result: PARTIAL PASS

Permit Number: SPRPL210327

Issuance Date: Sep 23, 2021

Property Address: 2305 MT WERNER CIR;

Contractor: MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

To construct: GSQ/KVC Plumbing reno

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: 124,125,126 water lines approved in boys, girls, and adult restrooms plus drinking fountains. Drinking fountain water lines in corridor just before room 167 approved, adult restroom 167 water lines approved, and rooms 170,169,168 and mop sink water lines approved. All water lines are stubbed out of bathroom areas into main corridor and capped, will need to re-inspect final tie into water mains in corridors. All lines held 100 psi for 15 minutes

Corrections:

Sincerely,

Todd Carr
Building Official
tcarr@co.routt.co.us