



INSPECTION REPORT

Report Issued: Oct 19, 2021

Inspection Result: PARTIAL PASS

Permit Number: SPRPL210472

Issuance Date: Oct 18, 2021

Property Address: 1863 RIVER QUEEN LN;

Contractor: MOUNTAIN HIGH MECHANICAL 6080 W 91ST CRT #2-104 WESTMINSTER, CO 80021 (970) 819-2690

To construct: Rough plumbing and trim for all fixtures on plans.

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Subslab DWV lines for house and garage drain have been installed and located to approved plans. Pressure test test good at 5 psi for 15 minutes on all zones.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us