



INSPECTION REPORT

Report Issued: Oct 19, 2021

Inspection Result: PARTIAL PASS

Permit Number: TB-21-865

Issuance Date: Aug 31, 2021

Property Address: 1863 RIVER QUEEN LN;

Contractor: Brstina LLC P.O. BOX 883321 STEAMBOAT SPGS, CO 80488 (970) 846-4030

To construct: Work Description: We will construct single family residence

Total valuation of the project is \$946,000 and \$800,000 is submitted as total valuation for the work requiring permits.

On this day we have inspected your construction for **Structural Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: 2 exterior pads have been formed and located to approved plans with all rebar sized and spaced correctly. Approved to pour. Radon pipe is stubbed up in west side of mechanical room.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us