



INSPECTION REPORT

Report Issued: Oct 20, 2021

Inspection Result: PARTIAL PASS

Permit Number: SPRPL210327

Issuance Date: Sep 23, 2021

Property Address: 2305 MT WERNER CIR;

Contractor: MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

To construct: GSQ/KVC Plumbing reno

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: rough plumbing for building A ski storage area approved for single bathroom for DWV and water lines, DWV is under 6 psi held for 15 minutes, water is live water pressure. Also inspected Building F DWV for the floor drain in water heater room, commercial washer drain, all held 6 psi for 15 minutes, will need to see completed studer vent in dryer room in future inspection. DWV has tied into existing plumbing lines, inspection were done on main floor above the ceiling to view all tie in work.

Corrections:

Sincerely,

Todd Carr
Building Official
tcarr@co.routt.co.us