



INSPECTION REPORT

Report Issued: Oct 27, 2021

Inspection Result: PARTIAL PASS

Permit Number: SPRPL210327

Issuance Date: Sep 23, 2021

Property Address: 2305 MT WERNER CIR;

Contractor: MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

To construct: GSQ/KVC Plumbing reno

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: KVC rough plumbing of water lines and DWV in room 118-119, DWV will need to be tied in below, but all DWV above floor and above ceiling approved, water lines approved as well at floor level and above ceiling, DWV held 6 psi and water held 100 psi, contractor adding a couple protective plates on studs, all water lines in kitchen room 111 approved held 100 psi at floor level and above ceiling approved, no DWV done in kitchen on this inspection

Corrections:

Sincerely,

Todd Carr
Building Official
tcarr@co.routt.co.us