



INSPECTION REPORT

Report Issued: Oct 28, 2021

Inspection Result: PARTIAL PASS

Permit Number: SPRMH210323

Issuance Date: Sep 23, 2021

Property Address: 2305 MT WERNER CIR;

Contractor: MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

To construct: KVC/GSQ TI Reno

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Building A level 2 partial approval of duct work, all ducts inspected have been sealed at the joints and supported properly, there a a few connection left to be made, bath exhaust and other ducts to be inspected next time. Building A level 3 duct work all approved, ducts are sealed and supported properly and sized per plans, minor deviations do the plans have been made but were approved through an RFI. Building F office area on east side all duct work is approved, sealed and supported properly and installed per plans.

Corrections:

Sincerely,

Todd Carr
Building Official
tcarr@co.routt.co.us