



# INSPECTION REPORT

**Report Issued:** Nov 03, 2021

**Inspection Result:** PARTIAL PASS

**Permit Number:** SPRPL210327

**Issuance Date:** Sep 23, 2021

**Property Address:** 2305 MT WERNER CIR;

**Contractor:** MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

**To construct:** GSQ/KVC Plumbing reno

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** DWV and water lines approved in laundry room, also approved main corridor water piping that made the tie into previous approved water lines for restrooms, drinking fountains, janitorial sinks on the entire east side, now fully completed, and approved the last adult restroom over by the kitchen area for water and DWV, all DWV held 6 psi and water held 100psi for 15 minutes, properly supported and protected.

**Corrections:**

Sincerely,

Todd Carr  
Building Official  
tcarr@co.routt.co.us