



INSPECTION REPORT

Report Issued: Nov 05, 2021

Inspection Result: NOT READY

Permit Number: B-21-625

Issuance Date: Jul 22, 2021

Property Address: 2305 MT WERNER CIR;

Contractor: Saunders Construction, LLC 86 Inverness Place North Englewood, CO 80112
(408) 656-9910

To construct: Work Description: The Work of Project is defined by the Contract Documents and consists of new construction and renovation of the Steamboat Base Village.

The work for the Goldwalk project includes a new entry walk, referred to as the Goldwalk.

On this day we have inspected your construction for **Drywall Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: not needed

Corrections:

Sincerely,

Todd Carr
Building Official
tcarr@co.routt.co.us