



INSPECTION REPORT

Report Issued: Nov 09, 2021

Inspection Result: PARTIAL PASS

Permit Number: SPRPL210563

Issuance Date: Nov 08, 2021

Property Address: 2305 MT WERNER CIR;

Contractor: MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

To construct: Plaza/Promenade new plumbing UG and AG

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: underslab DWV mains lower DWV approved in SE corner of basement of promenade building, from interceptor to promenade walk on east side, no connections to interceptor yet. held 6psi for 15 minutes, 2 cleanouts installed, 1 on 6" pipe and 1 on 4" pipe, from test ball at 6" cleanout back into the building

Corrections:

Sincerely,

Todd Carr
Building Official
tcarr@co.routt.co.us