



# INSPECTION REPORT

**Report Issued:** Nov 09, 2021

**Inspection Result:** PARTIAL PASS

**Permit Number:** SPRPL210327

**Issuance Date:** Sep 23, 2021

**Property Address:** 2305 MT WERNER CIR;

**Contractor:** MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

**To construct:** GSQ/KVC Plumbing reno

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Gas line in kitchen wall approved, held 11 psi for 15 minutes, strapped and supported and protected properly, tied into 3" main above, which will need to be tied into main gas line in future

**Corrections:**

Sincerely,

Todd Carr  
Building Official  
tcarr@co.routt.co.us