



# INSPECTION REPORT

**Report Issued:** Nov 10, 2021

**Inspection Result:** PARTIAL PASS

**Permit Number:** SPRPL210563

**Issuance Date:** Nov 08, 2021

**Property Address:** 2305 MT WERNER CIR;

**Contractor:** MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

**To construct:** Plaza/Promenade new plumbing UG and AG

On this day we have inspected your construction for **Approval for Service** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Storm drains in SE quadrant approved held 6 psi for 15 minutes

**Corrections:**

Sincerely,

Todd Carr  
Building Official  
tcarr@co.routt.co.us