



INSPECTION REPORT

Report Issued: Nov 10, 2021

Inspection Result: PARTIAL PASS

Permit Number: SPRPL210563

Issuance Date: Nov 08, 2021

Property Address: 2305 MT WERNER CIR;

Contractor: MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

To construct: Plaza/Promenade new plumbing UG and AG

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Gas fire pit gas line from fire pit to control access shutoff valve approved, held 10 psi for 15 minutes

Corrections:

Sincerely,

Todd Carr
Building Official
tcarr@co.routt.co.us