



# INSPECTION REPORT

**Report Issued:** Nov 10, 2021

**Inspection Result:** PARTIAL PASS

**Permit Number:** SPRMH210323

**Issuance Date:** Sep 23, 2021

**Property Address:** 2305 MT WERNER CIR;

**Contractor:** MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

**To construct:** KVC/GSQ TI Reno

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Building A 3rd floor final inspection items left to complete: Supply line not connected above sink in break area on east side, transfer gill for return air and duct work not completed across from restrooms, 6 inch line not connected down to 2nd floor which lies in the closet ceiling currently, 2 foot section of duct needed a VAV unit on far south side,

**Corrections:**

Sincerely,

Todd Carr  
Building Official  
tcarr@co.routt.co.us