



INSPECTION REPORT

Report Issued: Nov 12, 2021

Inspection Result: PARTIAL PASS

Permit Number: SPRMH210052

Issuance Date: Aug 19, 2021

Property Address: 2305 MT WERNER CIR;

Contractor: Saunders Construction, LLC 86 Inverness Place North Englewood, CO 80112 (408) 656-9910
CENTRAL ELECTRIC, LLC 2659 Jacob Cir #4 STEAMBOAT SPGS,, CO 80487 (970) 846-8379
MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

To construct: Install single boiler and install hydronic

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: approval for gas service to boiler room lower terminal approved. also view hydronic tubing in promenade area from escalator out to existing, including stage seating area as well, work in progress but R-5 installed beneath and tubing placed correctly, approved to keep under air and continue with sand and pavers, air gauge to remain on for final view.

Corrections:

Sincerely,

Todd Carr
Building Official
tcarr@co.routt.co.us