



INSPECTION REPORT

Report Issued: Nov 12, 2021

Inspection Result: **PARTIAL PASS**

Permit Number: B-21-625

Issuance Date: Jul 22, 2021

Property Address: 2305 MT WERNER CIR;

Contractor: Saunders Construction, LLC 86 Inverness Place North Englewood, CO 80112
(408) 656-9910

To construct: Work Description: The Work of Project is defined by the Contract Documents and consists of new construction and renovation of the Steamboat Base Village.

The work for the Goldwalk project includes a new entry walk, referred to as the Goldwalk.

On this day we have inspected your construction for **Framing Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Escalator and stair framing in progress, approved to date and proper steel studs size and spacing has been installed including fasteners, using fire rated plywood for all sheeting and is installed with proper fasteners and spacing, continue to forward.

Corrections:

Sincerely,

Todd Carr
Building Official
tcarr@co.routt.co.us