



INSPECTION REPORT

Report Issued: Nov 18, 2021

Inspection Result: PARTIAL PASS

Permit Number: SPRMH210611

Issuance Date: Nov 12, 2021

Property Address: 131 11TH ST;

Contractor: LARAMIE MECHANICAL & HEATING 602 SKYLINE RD LARAMIE, WY 82070
(307) 745-7255

To construct: replacing Make Up Air unit, adding duct work

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: New make up air ducts have installed and supported correctly to diffuser locations. Still need to seal up connections and joints.

Corrections:

- 1 Need to seal joints and connections at round to rectangle and round to round with mastic or clear silicone on exposed round duct.

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us