



INSPECTION REPORT

Report Issued: Nov 24, 2021

Inspection Result: PASSED

Permit Number: SPRGS210656

Issuance Date: Nov 24, 2021

Property Address: 131 11TH ST;

Contractor: TBH PLUMBING & HEATING P.O. BOX 882183 STEAMBOAT SPGS,, CO 80488
(970) 846-4702

To construct: Install 1-1/4" gas line from gas meter to Make up air unit.

On this day we have inspected your construction for **Approval for Service** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Exterior gas line approved from new rooftop unit to gas meter on alley held 16 psi and was properly supported across the roof.

Corrections:

Sincerely,

Todd Carr
Building Official
tcarr@co.routt.co.us