



# INSPECTION REPORT

**Report Issued:** Nov 30, 2021

**Inspection Result:** PARTIAL PASS

**Permit Number:** SPRMH210323

**Issuance Date:** Sep 23, 2021

**Property Address:** 2305 MT WERNER CIR;

**Contractor:** MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

**To construct:** KVC/GSQ TI Reno

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** KVC: Gas piping main approved to the kitchen area, this is a 3" line connected to piping previously inspected and approved, then over to a tee where it takes off to the air handling make-up unit on the roof for the kitchen, held pressure for 15 minutes to valve on roof, all gas piping installed and supported correctly, and connections to appliance approved on roof.

**Corrections:**

Sincerely,

Todd Carr  
Building Official  
tcarr@co.routt.co.us