



INSPECTION REPORT

Report Issued: Dec 10, 2021

Inspection Result: **FAILED**

Permit Number: SPREL210211

Issuance Date: Sep 08, 2021

Property Address: 2410 SKI TRAIL LN, UNIT:2802;

Contractor: CENTRAL ELECTRIC, LLC 2659 Jacob Cir #4 STEAMBOAT SPGS,, CO 80487
(970) 846-8379

To construct: Brand new kitchen, new appliances, new lighting.

On this day we have inspected your construction for **Electrical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Three pendants over kitchen island need to be installed GFI protection for dishwasher and refrigerator and garbage disposal recall when corrected

Corrections:

Sincerely,

Tom Cook
Electrical Plan Reviewer/Inspector
tcook@co.routt.co.us