



INSPECTION REPORT

Report Issued: Dec 13, 2021

Inspection Result: PASSED

Permit Number: SPRMH210719

Issuance Date: Dec 08, 2021

Property Address: 2305 MT WERNER CIR;

Applicant: Peter LiuMaui Mechanical, Inc.

Contractor: Maui Mechanical, Inc. 712 Clark Pl Colorado Springs, CO 80915 (719) 491-7397

To construct: Walk in refrigeration systems

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: rough inspection passed, line sets help under pressure for 30-minutes from two compressors set on west side of building exterior wall, lines ran up to the roof, then dropped down into the kitchen above the hood area, then ran over to walk-n-cooler. Contractor to add a couple support pads and mountain bracket to hold lines so they are not subject to lateral movement across the top of the coolers. All that is left is a final inspection once the coolers are running.

Corrections:

Sincerely,

Todd Carr
Building Official
tcarr@co.routt.co.us