



INSPECTION REPORT

Report Issued: Dec 14, 2021

Inspection Result: PASSED

Permit Number: SPRMH210274

Issuance Date: Sep 16, 2021

Property Address: 2410 SKI TRAIL LN;

Applicant: FIN'S TIN

Contractor: FIN'S TIN PO BOX 697 CLARK, CO 80428 (970) 846-7640

To construct: Hood Vent and Make up air.

On this day we have inspected your construction for **Mechanical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Make up air duct and exhaust duct for range hood installed properly and properly supported. All ducts sealed and insulated. Units operational. Approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us