



INSPECTION REPORT

Report Issued: Dec 16, 2021

Inspection Result: **FAILED**

Permit Number: SPRMH210676

Issuance Date: Dec 02, 2021

Property Address: 255 ANGLERS DR;

Applicant: Elevation Plumbing & Heating Inc.

Contractor: Elevation Plumbing & Heating Inc. 942 E. 8th Ave Broomfield, CO 80020 (303) 579-2269

To construct: Remove and replace pizza oven including new hood, grease duct and fan.

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: All equipment hooked up and unable to perform leakage test. Not Approved. Do not use equipment

Corrections:

- 1 Need to performed leakage test.

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us