



# INSPECTION REPORT

**Report Issued:** Dec 21, 2021

**Inspection Result:** PASSED

**Permit Number:** SPRMH210676

**Issuance Date:** Dec 02, 2021

**Property Address:** 255 ANGLERS DR;

**Applicant:** Elevation Plumbing & Heating Inc.

**Contractor:** Elevation Plumbing & Heating Inc. 942 E. 8th Ave Broomfield, CO 80020 (303) 579-2269

**To construct:** Remove and replace pizza oven including new hood, grease duct and fan.

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Pizza oven grease duct installed and passed smoke leakage test. Approved

**Corrections:**

- 1 Need to performed leakage test.

Sincerely,

Ron Norton  
Inspector  
rnorton@co.routt.co.us