



INSPECTION REPORT

Report Issued: Dec 21, 2021

Inspection Result: **PARTIAL PASS**

Permit Number: SPRPL210327

Issuance Date: Sep 23, 2021

Property Address: 2305 MT WERNER CIR;

Applicant: MTech Mechanical Technologies Group

Contractor: MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

To construct: GSQ/KVC Plumbing reno

On this day we have inspected your construction for **Plumbing Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Plumbing Final completely approved for KVC now Happy Campers for all plumbing work except laundry room sink that is not set yet.

Corrections:

- 1 Must complete install of Grease Interceptor to fully approve DWV Lines for kitchen branch of KVC for below slab work.
- 2 Need to inspect all vent lines above roof for DWV.
- 3 Final Inspection of all DWV and Water Piping required in regards to proper sealing of all penetrations through the slab from below, and CMU Walls, or other fire rated assemblies, this work to be done by Saunders.

Sincerely,

Todd Carr
Building Official



tcarr@co.routt.co.us