



# INSPECTION REPORT

**Report Issued:** Jan 13, 2022

**Inspection Result:** PASSED

**Permit Number:** TB-21-834

**Issuance Date:** Oct 06, 2021

**Property Address:** 1857 RIVER QUEEN LN;

**Applicant:**

**Contractor:** ALL JOEYS CONSTRUCTION INC POB 881524 STEAMBOAT SPRINGS, CO  
80488 (970) 531-1546

**To construct:** Work Description: Duplex Unit B

See Unit A, B-21-755 for valuation and fees

On this day we have inspected your construction for **Footing Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** 846-5268 Bill Unit B PM  
2 #4 bars throughout the whole footer, laps and spacing correct

**Corrections:**

Sincerely,

Jeff Yeiser  
Inspector  
jyeiser@co.routt.co.us