



INSPECTION REPORT

Report Issued: Jan 19, 2022

Inspection Result: PARTIAL PASS

Permit Number: SPRMH210774

Issuance Date: Dec 16, 2021

Property Address: 2305 MT WERNER CIR;

Applicant: MTech Mechanical Technologies Group

Contractor: MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

To construct: Boiler plant for heating and snowmelt water

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Piping for 3 UH-2 heater and 1 UH-3 in Gold Walk basement installed to Approved Plans. Heaters securely mounted and all piping is sized to plans and properly supported. Piping for heaters passed test of 100psi. Approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us