



INSPECTION REPORT

Report Issued: Feb 07, 2022

Inspection Result: PARTIAL PASS

Permit Number: TB-21-755

Issuance Date: Sep 28, 2021

Property Address: 1859 RIVER QUEEN LN;

Applicant:

Contractor: ALL JOEYS CONSTRUCTION INC POB 881524 STEAMBOAT SPRINGS, CO
80488 (970) 531-1546

To construct: Construct new duplex and detached garage

Unit A: B-21-755

Unit B: B-21-834

Detached Garage: B-21-835

On this day we have inspected your construction for **Foundation Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Partial: Open wall inspection performed on tall walls on both sides of foundation and are highlighted on Approved Plans. Rebar installed in these areas are sized and spaced correctly. Partial approved. Area to be inspected connects the two foundations.

Corrections:

Sincerely,



Ron Norton
Inspector
rnorton@co.routt.co.us