



# INSPECTION REPORT

**Report Issued:** Feb 28, 2022

**Inspection Result:**

**PARTIAL PASS**

**Permit Number:** SPRMH210774

**Issuance Date:** Dec 16, 2021

**Property Address:** 2305 MT WERNER CIR;

**Applicant:** MTech Mechanical Technologies Group

**Contractor:** MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

**To construct:** Boiler plant for heating and snowmelt water

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** 7 mini split heads installed and 7 condensers installed per Approved Plans. All equipment properly installed and all line sets test at 550psi. Approved. Will need to properly seal any penetrations that go through rated walls.

**Corrections:**

Sincerely,

Ron Norton  
Inspector  
rnorton@co.routt.co.us