



INSPECTION REPORT

Report Issued: Mar 23, 2022

Inspection Result: PARTIAL PASS

Permit Number: TB-21-865

Issuance Date: Aug 31, 2021

Property Address: 1863 RIVER QUEEN LN;

Applicant: Srdjan Brstina

Contractor: Brstina LLC P.O. BOX 883321 STEAMBOAT SPGS, CO 80488 (970) 846-4030

To construct: Work Description: We will construct single family residence

Total valuation of the project is \$946,000 and \$800,000 is submitted as total valuation for the work requiring permits.

On this day we have inspected your construction for **Framing Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Partial Masonry inspection: Across front of garage and down both sides has 2 layers of felt paper installed with properly spaced weep ropes. Stone will sit on foundation brick ledge and wall ties installed. Steel lintel installed over garage door and windows. Partial approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us