



INSPECTION REPORT

Report Issued: Mar 31, 2022

Inspection Result: PARTIAL PASS

Permit Number: SPREL210226

Issuance Date: Sep 09, 2021

Property Address: 2305 MT WERNER CIR;

Applicant: CENTRAL ELECTRIC, LLC

Contractor: CENTRAL ELECTRIC, LLC 2659 Jacob Cir #4 STEAMBOAT SPGS,, CO 80487
(970) 846-8379

To construct: Add new power, lighting, site lighting & gear for Promenade

On this day we have inspected your construction for **Electrical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Deep underground lower level 00 approved

Corrections:

Sincerely,

Tom Cook
Electrical Plan Reviewer/Inspector
tcook@co.routt.co.us