



INSPECTION REPORT

Report Issued: Apr 08, 2022

Inspection Result: PASSED

Permit Number: SPRPL210472

Issuance Date: Oct 18, 2021

Property Address: 1863 RIVER QUEEN LN;

Applicant: MOUNTAIN HIGH MECHANICAL

Contractor: MOUNTAIN HIGH MECHANICAL 6080 W 91ST CRT #2-104 WESTMINSTER, CO 80021 (970) 819-2690

To construct: Rough plumbing and trim for all fixtures on plans.

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: DWV and water, pressure test of 6 psi and 5.5 psi, both held. Water lines run to all locations, all DWV stacks finished.

Corrections:

Sincerely,

Jeff Yeiser
Inspector
jyeiser@co.routt.co.us