



INSPECTION REPORT

Report Issued: Apr 08, 2022

Inspection Result: PARTIAL PASS

Permit Number: SPRMH210469

Issuance Date: Oct 18, 2021

Property Address: 1863 RIVER QUEEN LN;

Applicant: MOUNTAIN HIGH MECHANICAL

Contractor: MOUNTAIN HIGH MECHANICAL 6080 W 91ST CRT #2-104 WESTMINSTER, CO 80021 (970) 819-2690

To construct: Infloor heat with lochonvar boiler. HRV for whole house ventilation.

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Gas line and duct work for HRV vent fan. Gas line installed, held 20psi. Vent ducts in all baths and kitchen cement sealed. HRV not installed

Corrections:

Sincerely,

Jeff Yeiser
Inspector
jyeiser@co.routt.co.us