



INSPECTION REPORT

Report Issued: Apr 20, 2022

Inspection Result: PARTIAL PASS

Permit Number: SPRPL210563

Issuance Date: Nov 08, 2021

Property Address: 2305 MT WERNER CIR;

Applicant: MTech Mechanical Technologies Group

Contractor: MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000
Holly Klein 12300 Pecos Street Westminster, CO 80234 (303) 650-4000

To construct: Plaza/Promenade new plumbing UG and AG

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: hydronic line from interior side of parking lot garage east wall, ran supply and return lines suspended from ceiling, into boiler room, then a right turn back out and connected to existing lines, this is a main feed from promenade building to garage and the lines under the promenade were inspected last year and capped in the new basement area. Will need to see insulation and caulking later.

Corrections:

Sincerely,

Todd Carr
Building Official
tcarr@co.routt.co.us