



# INSPECTION REPORT

**Report Issued:** May 02, 2022

**Inspection Result:** PASSED

**Permit Number:** TB-21-865

**Issuance Date:** Aug 31, 2021

**Property Address:** 1863 RIVER QUEEN LN;

**Applicant:** Srdjan Brstina

**Contractor:** Brstina LLC P.O. BOX 883321 STEAMBOAT SPGS, CO 80488 (970) 846-4030

**To construct:** We will construct single family residence

On this day we have inspected your construction for **Drywall Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** 5/8 Type X drywall installed on garage lid and properly fastened. Approved

**Corrections:**

Sincerely,

Ron Norton  
Inspector  
rnorton@co.routt.co.us