



INSPECTION REPORT

Report Issued: May 02, 2022

Inspection Result: PASSED

Permit Number: SPRMH220489

Issuance Date: Apr 28, 2022

Property Address: 1863 RIVER QUEEN LN;

Applicant: MOUNTAIN HIGH MECHANICAL

Contractor: MOUNTAIN HIGH MECHANICAL 6080 W 91ST CRT #2-104 WESTMINSTER, CO
80021 (970) 819-2690

To construct: Venting new fireplaces.

On this day we have inspected your construction for **Mechanical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: clearance and draft stop corrections made. Unit is properly vented and gas line hooked up

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us