

## Malea Michael-Ferrier

---

**From:** Brittany Wall <Brittany@darbyenterprises.com>  
**Sent:** Tuesday, May 10, 2022 1:40 PM  
**To:** Malea Michael-Ferrier  
**Subject:** FW: Permit SPRRF220556, 405 Anglers Dr

Hi,  
Please see our responses below. Please let me know if you need anything else or have any other questions.

Thank you,

**Brittany Wall**  
*Office Administrator*  
**Darby Enterprises, Inc.**  
1801 W Irvington Pl  
Denver, CO 80223  
Ph: 303.430.0251  
Fax: 303.430.1098

---

**From:** Aaron Whitener <Aaron@darbyenterprises.com>  
**Sent:** Tuesday, May 10, 2022 1:25 PM  
**To:** Brittany Wall <Brittany@darbyenterprises.com>  
**Subject:** RE: Permit SPRRF220556, 405 Anglers Dr

1. Please submit the layout for the tapered system (you can email it to me)
  - a. The roof is structurally tapered when it was originally built. No taper system will be added.
2. Does the whole roof drain to the back of the building? Are there drains, scuppers or is it all drip edge?
  - a. Everything drains to the drip edge on the south side of the building.
3. Are you only doing the flat roof?
  - a. Yes, it's only the flat roof unless there are minor to the shingles needed to tie-in the flat at the vertical junctions.

**Aaron Whitener**  
Darby Enterprises, Inc.

1801 W. Irvington Pl | Denver, CO 80223  
O: 303-430-0251 | C: 720-320-2232  
[www.darbyenterprises.com](http://www.darbyenterprises.com)

---

*This message (including any attachments) may contain confidential, proprietary, privileged and/or private information. The information is intended to be for the use of the individual or entity designated above. If you are not the recipient of this message, please notify the sender immediately.*

---

**From:** Brittany Wall  
**Sent:** Tuesday, May 10, 2022 1:16 PM  
**To:** Aaron Whitener <[Aaron@darbyenterprises.com](mailto:Aaron@darbyenterprises.com)>  
**Subject:** FW: Permit SPRRF220556, 405 Anglers Dr

---

**From:** Malea Michael-Ferrier <[mmichael-ferrier@co.routt.co.us](mailto:mmichael-ferrier@co.routt.co.us)>  
**Sent:** Tuesday, May 10, 2022 1:08 PM  
**To:** Brittany Wall <[Brittany@darbyenterprises.com](mailto:Brittany@darbyenterprises.com)>  
**Subject:** FW: Permit SPRRF220556, 405 Anglers Dr

---

**From:** Malea Michael-Ferrier  
**Sent:** Tuesday, May 10, 2022 10:24 AM  
**To:** 'DRBYROOFS@AOL.COM' <[DRBYROOFS@AOL.COM](mailto:DRBYROOFS@AOL.COM)>  
**Subject:** Permit SPRRF220556, 405 Anglers Dr

Good morning-

I have a couple questions regarding this roof system:

1. Please submit the layout for the tapered system (you can email it to me)
2. Does the whole roof drain to the back of the building? Are there drains, scuppers or is it all drip edge?
3. Are you only doing the flat roof?

Thank you,  
Malea

**Malea Michael-Ferrier**



Routt County Regional Building Dept.  
136 6th Street, Ste 201  
Steamboat Springs, CO 80487  
970-870-5566  
[mmichael-ferrier@co.routt.co.us](mailto:mmichael-ferrier@co.routt.co.us)

### **Disclaimer**

The information contained in this communication is confidential and intended solely for use by the recipient(s). If you are not the recipient, understand that any disclosure or distribution of the contents is strictly prohibited and may be unlawful. This email has been scanned for viruses and malware, and may have been automatically archived.