



# INSPECTION REPORT

**Report Issued:** May 19, 2022

**Inspection Result:** PASSED

**Permit Number:** SPREL210226

**Issuance Date:** Sep 09, 2021

**Property Address:** 2305 MT WERNER CIR;

**Applicant:** CENTRAL ELECTRIC, LLC

**Contractor:** CENTRAL ELECTRIC, LLC 2659 Jacob Cir #4 STEAMBOAT SPGS,, CO 80487  
(970) 846-8379

**To construct:** Add new power, lighting, site lighting & gear for Promenade

On this day we have inspected your construction for **Electrical Perm Service** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Permanent electrical service approved

**Corrections:**

Sincerely,

Tom Cook  
Electrical Plan Reviewer/Inspector  
tcook@co.routt.co.us