



## **INSPECTION REPORT**

Report Issued:	May 25, 2022	Inspection Resu	ilt:	PARTIAL PASS
		•		
Permit Number:	TB-21-835			
Issuance Date:	Apr 01, 2022			
Property Address:	1859 RIVER QUEEN LN;			
Applicant:				
Contractor:	ALL JOEYS CONSTRUCTION INC POB 881524 STEAMBOAT SPRINGS, CO			
	80488 (970) 531-1546			
To construct:	Work Description: Detached shared garage for duplex.			
	Permits for duplex are:			
	Unit A: B-21-755			
	Unit B: B-21-835			

On this day we have inspected your construction for **Foundation Drain Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Partial: SDR pipe installed across front of garage and down southside to back of foundation. Pipe is properly bedded in gravel with proper fall. Partial approved

See B-21-755 for valuation and fees.

## **Corrections:**

Sincerely,

Ron Norton





Inspector rnorton@co.routt.co.us