



# INSPECTION REPORT

**Report Issued:** Jun 02, 2022

**Inspection Result:** PASSED

**Permit Number:** SPRAB220362

**Issuance Date:** Apr 28, 2022

**Property Address:** 2305 MT WERNER CIR;

**Applicant:** STEAMBOAT SKI & RESORT CORP

**Contractor:** STEAMBOAT SKI & RESORT CORP. 2305 MT WERNER CIR STEAMBOAT SPRINGS, CO 80487-9023

**To construct:** Replace the existing underground Bashor snowmaking valve control building, with a new, confined space compliant building set into the hillside for direct access and egress.

Parcel Number should be 936271001 it would not give that one as a choice.  
Tammy

On this day we have inspected your construction for **Footing Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Footings for Blockhouse sized to Approved Plans. Rebar installed is sized and spaced correctly. Ufer wire properly installed. Approved

**Corrections:**

Sincerely,

Ron Norton  
Inspector  
rnorton@co.routt.co.us