



INSPECTION REPORT

Report Issued: Jun 03, 2022

Inspection Result: PARTIAL PASS

Permit Number: TB-21-834

Issuance Date: Oct 06, 2021

Property Address: 1857 RIVER QUEEN LN;

Applicant:

Contractor: ALL JOEYS CONSTRUCTION INC POB 881524 STEAMBOAT SPRINGS, CO
80488 (970) 531-1546

To construct: Work Description: Duplex Unit B

See Unit A, B-21-755 for valuation and fees

On this day we have inspected your construction for **Foundation Drain Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Partial: Foundation drain installed from center cleanout on front house moving around to back northwest corner on back of house. Pipe is properly bedded in gravel and cover in filter fabric. Partial approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us