



# INSPECTION REPORT

**Report Issued:** Jun 06, 2022

**Inspection Result:** PASSED

**Permit Number:** SPRPL220628

**Issuance Date:** May 22, 2022

**Property Address:** 345 LINCOLN AVE, UNIT:205;

**Applicant:** Isidro Quezada

**Contractor:** IQ PLUMBING & HEATING 895 RANNEY ST CRAIG, CO 81625 (970) 629-5125

**To construct:** Install new drains and water lines to commercial unit. It will consist of 3 bathrooms a kitchen and a mechanical/laundry room.

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Baths, kitchen and laundry roughs. Shower valves installed, water holding pressure. Drains flooded, ceiling below open for leak check.

**Corrections:**

Sincerely,

Jeff Yeiser  
Inspector  
jyeiser@co.routt.co.us