



## **INSPECTION REPORT**

Report Issued: Jun 14, 2022 Inspection Result: PARTIAL PASS

Permit Number: SPRPL210563 Issuance Date: Nov 08, 2021

Property Address: 2305 MT WERNER CIR;

**Applicant:** MTech Mechanical Technologies Group

Contractor: MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co

80234 (719) 782-4000Holly Klein 12300 Pecos Street Wesminster, CO 80234

(303) 650-4000

To construct: Plaza/Promenade new plumbing UG and AG

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Balance of under slab DWV and grease lines completed to Approved Plans and revisions. Remaining 2 group passed test of 5psi.

## **Corrections:**

Sincerely,

Ron Norton Inspector rnorton@co.routt.co.us