



INSPECTION REPORT

Report Issued: Jun 16, 2022

Inspection Result: PARTIAL PASS

Permit Number: TB-21-865

Issuance Date: Aug 31, 2021

Property Address: 1863 RIVER QUEEN LN;

Applicant: Srdjan Brstina

Contractor: Brstina LLC P.O. BOX 883321 STEAMBOAT SPGS, CO 80488 (970) 846-4030

To construct: We will construct single family residence

On this day we have inspected your construction for **Structural Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Partial: 2 shower pans installed in lower level. Shower pans sealed and held water for test duration. Approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us