



INSPECTION REPORT

Report Issued: Jul 20, 2022

Inspection Result: **FAILED**

Permit Number: SPREL220993

Issuance Date: Jul 19, 2022

Property Address: 1805 WALTON CREEK RD;

Applicant: CURRENT ELECTRICAL CONT.

Contractor: CURRENT ELECTRICAL CONT. 28395 cr 18 steamboat, CO 80487 (970) 846-1970

To construct: town homes

On this day we have inspected your construction for **Electrical Temp Service** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: High voltage cubicle not usable voltage

Corrections:

Sincerely,

Tom Cook
Electrical Plan Reviewer/Inspector
tcook@co.routt.co.us