



INSPECTION REPORT

Report Issued: Jul 26, 2022

Inspection Result: **PARTIAL PASS**

Permit Number: SPRPL220733

Issuance Date: Jun 06, 2022

Property Address:

Applicant: Mechanical & Piping Inc

Contractor: Mechanical & Piping Inc 6440 E. 50th Ave Commerce City, CO 80022 (303) 710-2869

To construct: New Restaurant and Rest room, Wild Blue Gondola Mid Mountain.

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: 4 Inch floor drain and stack in boiler room installed and pass test of 5.5psi.
Approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us