



INSPECTION REPORT

Report Issued: Jul 27, 2022

Inspection Result: **PARTIAL PASS**

Permit Number: SPRPL220977

Issuance Date: Jul 18, 2022

Property Address: 2305 MT WERNER CIR;

Applicant: Michael KmetzCanyon Plumbing Inc.

Contractor: Canyon Plumbing Inc. 29350 Industrial Way #210 Evergreen, CO 80439

To construct: furnish and install underground waste pipe, wall rough, plumbing fixtures, floor drains, floor sinks, drinking fountains, water pipe and insulation, water heater, mop sink, recirc pump.

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Sub slab DWV installed for floor drains. DWV passed test of 5psi. Plans not consistent with what is installed. Contractor is submitting amended plans for review. Cover at own risk. Conditionally approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us