



INSPECTION REPORT

Report Issued: Aug 05, 2022

Inspection Result: PASSED

Permit Number: SPRPL220977

Issuance Date: Jul 18, 2022

Property Address: 2305 MT WERNER CIR;

Applicant: Michael KmetzCanyon Plumbing Inc.

Contractor: Canyon Plumbing Inc. 29350 Industrial Way #210 Evergreen, CO 80439

To construct: furnish and install underground waste pipe, wall rough, plumbing fixtures, floor drains, floor sinks, drinking fountains, water pipe and insulation, water heater, mop sink, recirc pump.

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: DWV and waterlines for 2 bathroom groups and water fountain installed to Approved Plans. Waterline and drain for New RTU installed. All pipes supported and protected. DWV test is good at 5psi and waterlines are good at 100psi. Approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us