



INSPECTION REPORT

Report Issued: Aug 10, 2022

Inspection Result: **PARTIAL PASS**

Permit Number: TB-21-865

Issuance Date: Aug 31, 2021

Property Address: 1863 RIVER QUEEN LN;

Applicant: Srdjan Brstina

Contractor: Brstina LLC P.O. BOX 883321 STEAMBOAT SPGS, CO 80488 (970) 846-4030

To construct: Construct single family residence

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: All work completed and good to CO after passing final for SPRMH210469. Partial approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us