



INSPECTION REPORT

Report Issued: Aug 12, 2022

Inspection Result: **PARTIAL PASS**

Permit Number: SPRMH221087

Issuance Date: Aug 03, 2022

Property Address: 1859 RIVER QUEEN LN;

Applicant: BB PLUMBING & HEATING

Contractor: BB PLUMBING & HEATING P.O. BOX 771102 STEAMBOAT SPGS, CO 80477
(970) 846-7331

To construct: in floor heat and bathroom fans

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Radon pipe properly installed in both units to above slab. Approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us